UptîmeInstitute[®]

4 April 2019

Mr. Andres Arturo Diaz Montes Regional Manager of Network and Telephony Engineering IFX Networks Colombia S.A.S. Diagonal 97 # 17-60 Piso 4 Bogotá, DC - 110221 Colombia

Re: Tier III Certification of Design Documents for the IFX Networks Colombia S.A.S. – Jupiter Data in Bogotá, Colombia

Dear Mr. Andres Arturo Diaz Montes,

Uptime Institute Professional Services is pleased to announce the Tier Certification of Design Documents for the IFX Networks Colombia S.A.S. – Jupiter Data as fulfilling Tier III Concurrently Maintainable criteria. This Certification is based upon the design documentation submitted between 26 November 2018 and 29 March 2019.

This Certification recognizes the IFX Networks Colombia S.A.S. – Jupiter Data design, as supporting any planned work on the site infrastructure without disrupting operations, as limited by the stated IT capacity of 189 kilowatts (kW). Server Room – Module 1 is certified to support a critical IT load of up to 49 kW. Server Room – Module 2 is certified to support a critical IT load of up to 54 kW. Server Room – Module 3 is certified to support a critical IT load of up to 43 kW. Server Room – Module 4 is certified to support a critical IT load of up to 43 kW.

Tier III Concurrently Maintainable criteria are founded on the capability to complete planned facility maintenance or modifications on a scheduled basis; equipment failures or distribution path faults may lead to unplanned outages. Certain operator errors, such as procedural errors during reconfiguration of the redundant computer room or site infrastructure equipment, may also impact the critical load.

This Tier Certification is based on the 100% design documents as submitted for review and makes no assurances as to the constructed environment. This Tier Certification is valid until the design is modified, including any changes to the capacity components or distribution paths depicted in the design identified above and submitted for review. This Certification is subject to the limitations set forth in Schedule I, attached hereto and incorporated herein.

The Tier III Certification of Design Documents award is valid until 4 April 2021 subject to the limitations and extension request process set forth in the attached Schedule I.

Congratulations on this achievement.

Sincerely,

hristophen Br

Christopher Brown Chief Technical Officer